

## Micro Embedded Generation Facility Connection Agreement

In consideration of Niagara Peninsula Energy Inc agreeing to allow you to connect your 10 kW name-plate rated capacity or smaller generation facility to Niagara Peninsula Energy Inc.'s distribution system, you hereby agree to the following terms and conditions.

### 1.0 Eligibility

1.1 You agree that your generation connection shall be subject to all applicable laws and bound by the Terms and Conditions of the Niagara Peninsula Energy Inc. Conditions of Service as amended from time-to-time, which have been filed with the OEB and are available on request.

### 2.0 Technical Requirements

2.1 You represent and warrant that you have installed or will install prior to the connection of your generation facility to the Niagara Peninsula Energy Inc.'s distribution system, an isolation device satisfying Section 84 of the Ontario Electrical Safety Code and agree to allow Niagara Peninsula Energy Inc.'s staff access to and operation of this as required for the maintenance and repair of the distribution system.

2.2 You agree to perform regular scheduled maintenance to your generation facility as outlined by the manufacturer in order to assure that connection devices, protection systems, and control systems are maintained in good working order and in compliance with all applicable laws.

2.3 You agree that during a power outage on Niagara Peninsula Energy Inc.'s system your generation facility will shut down, unless you have installed special transfer and isolating capabilities on your generation facility. You agree to the automatic disconnection of your generation facility from Niagara Peninsula Energy Inc.'s distribution system, as per the generator protective relay settings set out in this Agreement, in the event of a power outage on Niagara Peninsula Energy Inc.'s distribution system or any abnormal operation of Niagara Peninsula Energy Inc.'s distribution system.

2.4 You covenant and agree that the design, installation, maintenance, and operation of your generation facility are conducted in a manner that ensures the safety and security of both the generation facility and Niagara Peninsula Energy Inc.'s distribution system.

2.5 Due to Niagara Peninsula Energy Inc.'s obligation to maintain the safety and reliability of its distribution system, you acknowledge and agree that in the event Niagara Peninsula Energy Inc. determines that your generation facility (i) causes damage to; and/or (ii) is producing adverse effects affecting other distribution system customers or Niagara Peninsula Energy Inc.'s assets, you will disconnect your generation facility immediately from the distribution system upon direction from Niagara Peninsula Energy Inc. and correct the problem at your own expense prior to reconnection.

### 3.0 Liabilities

3.1 You and Niagara Peninsula Energy Inc. will indemnify and save each other harmless for all damages and/or adverse effects resulting from either party's negligence or willful misconduct in the connection and operation of your generation facility or Niagara Peninsula Energy Inc.'s distribution system.

3.2 Niagara Peninsula Energy Inc. and you shall not be liable to each other under any circumstances whatsoever for any loss of profits or revenues, business interruptions losses, loss of contract or loss of goodwill, or for any indirect, consequential, incidental or special damages, including but not limited to punitive or exemplary damages, whether any of the said liability, loss or damages arise in contract, tort or otherwise.



Our energy works for you.

Head Office: 7447 Pin Oak Drive Box 120 Niagara Falls, Ontario L2E 6S9
T: 905-356-2881 Toll Free: 1-877-270-3938
F: 905-356-0118 E: info@npei.ca www.npei.ca

4.0 Compensation and Billing

4.1 If you are not an embedded retail generator, you agree that, subject to any applicable law:
a. Niagara Peninsula Energy Inc. will not pay you for any excess generation that results in a net delivery to Niagara Peninsula Energy Inc. between meter reads; and
b. There will be no carryover of excess generation from one billing period to the next unless you are, at the relevant time, a net metered generator (as defined in section 6.7.1 of the Distribution System Code).

4.2 If you are an embedded retail generator selling output from the embedded generation facility to the Ontario Power Authority under contract, you agree that Niagara Peninsula Energy Inc. will pay you for generation in accordance with the Retail Settlement Code.

4.3 If you are an embedded retail generator delivering and selling output to Niagara Peninsula Energy Inc., you agree that Niagara Peninsula Energy Inc. will pay you for generation in accordance with the Retail Settlement Code.

5.0 Termination

5.1 You understand that you have the right to terminate this agreement at any time, and that by doing so you are required to disconnect your generation facility and notify Niagara Peninsula Energy Inc. of such action.

6.0 Assignment

6.1 You may assign your rights and obligations under this Agreement with the consent of Niagara Peninsula Energy Inc., which shall not withhold its consent unreasonably. Niagara Peninsula Energy Inc. shall have the right to assign its rights and obligations under this Agreement without your consent.

I understand, accept and agree to comply with and be bound by the above terms and conditions governing the connection of my generation facility to Niagara Peninsula Energy Inc.'s distribution system.

I confirm that the following information is true and accurate.

Micro Generation Address: \_\_\_\_\_

Table with 2 columns: Distributor Signature, Customer Signature. Rows include Name (Print) and Date.

Nameplate Rating of Generator: \_\_\_\_\_ kW



Our energy works for you.

Head Office:  
7447 Pin Oak Drive  
Box 120  
Niagara Falls, Ontario  
L2E 6S9

T: 905-356-2681  
Toll Free: 1-877-270-3938  
F: 905-356-0118  
E: info@npei.ca  
www.npei.ca

Total Installed Generation: \_\_\_\_\_ kW

Type of Generation:  Photovoltaic (Solar)  Wind Turbine  Hydraulic Turbine  Fuel Cell  
 Other: \_\_\_\_\_

Inverter Utilized?  Yes  No

Inverter Certification:  C22.2 #107.1  UL 1741  Site Certified by the ESA

For Niagara Peninsula Energy Inc.'s Use:

Niagara Peninsula Energy Inc. Account Number: \_\_\_\_\_

Feeder: \_\_\_\_\_ Station: \_\_\_\_\_

Date Connected: \_\_\_\_\_

Generator Protective  
Relay Settings

**Table 1-Inverter-Based Generation**

The following relay settings shall be used for inverters built to the CSA standard:

Source: CSA C22.2 No. 107.1-01 Table 16

System Voltage $V_n$ ' V nominal <b>V (Volts)</b>	Frequency <b>F (Hertz)</b>	Maximum Number of Cycles to Disconnect	
		Seconds	Cycle
$V < 0.5 V_n$	60	0.1	6
$0.5 V_n \leq V < 0.88 V_n$	60	2	120
$1.10 V_n \leq V < 1.37 V_n$	60	2	120
$V > 1.37 V_n$	60	0.033	2
$V_n$	$F < 59.5^*$	0.1	6
$V_n$	$F > 60.5$	0.1	6

\*The UL1741 & IEEE P1547 Standards use  $F < \text{rated} - 0.7$  i.e. 59.3 Hz. To update if CSA C22.2 No. 107.1-01 is changed

**Table 2- Non-Inverter Generation**

Niagara Peninsula Energy Inc.'s minimum requirements, for other generation are as follows:

System Voltage $V_n$ ' V nominal <b>V (Volts)</b>	Frequency <b>F (Hertz)</b>	Maximum Clearing time*	
		Seconds	Cycle
$V < 0.5 V_n$	60	0.16	9.6
$0.5 V_n \leq V < 0.88 V_n$	60	2	120
$1.10 V_n \leq V < 1.20 V_n$	60	1	60
$V \geq 1.20 V_n$	60	0.16	9.6
$V_n$	$F < 59.3$	0.16	9.6
$V_n$	$F > 60.5$	0.16	9.6

\*Clearing time is the time between the start of the abnormal condition and the generation ceasing to energize Niagara Peninsula Energy Inc.'s distribution system.

- If you are uncertain about your generation equipment's protective relay settings, please check with your generating equipment supplier.
- Automatic reconnect setting time for your generator is after 5 minutes of normal voltage and frequency on Niagara Peninsula Energy Inc.'s distribution system.